



GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI



FORM - 18(2)

FORM - (G)

Dated Guwahati the 13/6/22

NO. F&ES/FPW/1026/7951/22

The Principal,
St. Clare's Convent High School,
Borjhar, Guwahati-15,
Dist:- Kamrup (M), Assam.

RENEWAL OF NO OBJECTION CERTIFICATE IN RESPECT OF INBUILT FIRE FIGHTING, FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN **THE ST. CLARE'S CONVENT HIGH SCHOOL LOCATED AT BORJHAR, GUWAHATI-15, DIST:- KAMRUP (M), ASSAM.**

With reference to your completion report under No. Nil Dated 04.06.2022 and on the basis of the Inspection Report submitted by Asst. Fire Prevention Officer, Biswajit Baishya, I hereby certify that the building as per description below at Dag No. 76, 78, 43, 81, 30 Patta No. 158, 370, 34, 197, 208 Mouza **Dakhin Rani**, (Place- Borjhar, Guwahati-5) has been inspected in respect of implementation of inbuilt Fire Fighting/ Fire Prevention/ Escape means measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has No Objection in its occupation /utilization for the purpose of **SCHOOL** subject to conditions mentioned over leaf.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR:-

1. Floor area: - 1706 m²

2. Purpose of utilization: -
For Office, Guest Hall and Classroom etc.

FIRST FLOOR:-

1. Floor area: - 1706 m²

2. Purpose of utilization: -
For Classroom Purpose.

SECOND FLOOR:-

1. Floor area: - 1373 m²

2. Purpose of utilization:-
For Classroom Purpose.

Details of inbuilt Fire Fighting and Fire Prevention measures:

1. Hose Reel Hose system
2. Down Comer system
3. Manually Operated Electric Fire Alarm system
4. Fire Extinguishers-26 Nos.
5. Terrace Water Tank
6. Terrace Pump

S.P. cum F&ES Adviser,
Fire & Emergency Services, Assam
Director of Fire and Emergency Services,
Assam, Guwahati

Dated Guwahati the

NO. F&ES/FPW/

Copy to:-

1. The Deputy Commissioner, Kamrup (M), Assam for information.
2. The Commissioner of Police, Kamrup (M), Assam for information.
3. The Commissioner/ Chairman, G.M.C. Guwahati, Assam for information.
4. The Sr. Station Officer, Pandu F&ES Station, for information and necessary action.

Maris
PRINCIPAL

St. Clare's Convent High School
Borjhar, Ghy-15
Dist : Kamrup (Assam)

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati

Gray
MANAGER
St. Clare's Convent High School
Borjhar, Ghy-15
Kamrup (Assam)

(((2)))

CONDITIONS:-

1. The N.O.C. is valid up to: - **31.03.2023**
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically.
There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time.
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
7. **The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.**

S.P. Curran & E.S.A.
for Fire & Emergency Services, Assam
Director of Fire & Emergency Services,
Pan Bazar, Guwahati-1
Assam, Guwahati.

Maris

PRINCIPAL

St. Clare's Convent High School
Borjhar, Ghy-15
Dist : Kamrup (Assam)

Gracy
MANAGER
Clare's Convent High School
Borjhar, Ghy-15
Dist : Kamrup (Assam)